



USFOR-A FIRE SAFETY
318-449-4271
TASK FORCE POWER
318-449-4297

DEPARTMENT OF DEFENSE
 HEADQUARTERS, US FORCES-AFGHANISTAN
 NEW KABUL COMPOUND, KABUL, AFGHANISTAN
 APO AE 09356

USFOR-A SAFETY
318-449-4830
USFOR-A(S) SAFETY
318-421-7434



SAFETY INSPECTIONS CONTINUE TO NOTE FACILITIES USING ELECTRICAL POWER STRIPS NOT CERTIFIED BY INTERNATIONALLY RECOGNIZED PRODUCT SAFETY AUTHORITIES. USE OF THESE ITEMS POSE A SERIOUS SAFETY ISSUE AND ARE LINKED TO MULTIPLE ELECTRICAL FIRES THROUGHOUT AFGHANISTAN.



ELECTRICAL POWER STRIPS WILL BE UNDERWRITERS LABORATORY (UL), OR CONFORMANCE EUROPEAN (CE) CERTIFIED. THE REGULATORY CERTIFICATION MARKS ARE SHOWN BELOW. THESE LOGOS ARE NORMALLY STAMPED INTO THE PLASTIC CASING OR AFFIXED TO THE PRODUCT ON A SQUARE METALLIC HOLOGRAM.



Underwriters
 Laboratories Logo



Conformance
 European Logo

*Think Safety
 First!
 Not Last!*

APPROVED POWER STRIPS ARE AVAILABLE FROM THESE GSA GLOBAL SUPPLY NSNs:

Power rating

- 110v/125v
- 110v/125v
- 110v/125v
- 110v/125v
- 220v/240v

NSN

- 5920-01-490-6691
- 5290-01-384-8597
- 5920-01-422-8851
- 5920-01-422-8867
- 6150-01-237-6517

S
A
F
E
T
Y

A
L
E
R
T

S
A
F
E
T
Y

A
L
E
R
T

S
A
F
E
T
Y

A
L
E
R
T

S
A
F
E
T
Y

A
L
E
R
T