



USFOR-A FIRE SAFETY  
318-449-4271

# USFOR-A SAFETY ALERT

USFOR-A SAFETY  
318-449-4830



## FIRE / ELECTROCUTION HAZARD

**UNSAFE TRANSFORMERS / POWER CONVERTERS ARE RESPONSIBLE FOR AT LEAST ONE RECENT MAJOR FIRE AND ONE ELECTROCUTION**



Ensure personnel are informed of the danger and have them conduct inspections of their work and living areas for non-compliant electrical equipment. **DO NOT USE THESE ITEMS.**



**NON-RATED CONVERTERS**



- GOLDSOURCE
- MATSUNAGA STAVOL
- AIHSAN
- SUPER GENERAL
- AKIRA

These transformers and other electrical equipment currently in use that do not conform to Underwriters Laboratory (UL), European Marking of Conformity (CE) or equivalent nationally recognized safety requirements will be taken out of service immediately.



**CJOA FIRE PREVENTION GUIDE**  
15 MAY 08



**5.9 Electrical Equipment:** Electrical equipment and its installation will conform to NFPA 70, National Electrical Code and shall meet Underwriters Laboratory (UL), European Marking of Conformity (CE) or equivalent nationally recognized safety requirements. Operation of all electrical equipment will be discontinued immediately upon recognition of an unsafe or hazardous condition.



**NON-RATED PLUG ADAPTERS**