



ELECTRICAL HAZARDS

ELECTRICAL PANEL BOX

Electrical hazards have caused electrical shocks, electrocutions (fatalities), equipment damage and fires.

Contributing Factors

- Improper wiring or splicing into electrical panel box
- Improper grounding or bonding electrical panel box
- Improper storage of combustible materials near electrical panel box


Corrective Measures

- Report all electrical hazards to the Safety Officer/NCO and Mayor Cell immediately
- Do not store combustible materials near electrical panel boxes
- Do not place fire extinguisher in front of or next to electrical panel boxes

Soldiers and civilians will not open or tamper with electrical panel boxes and will report all unsecured electrical panel boxes to the Safety Officer/NCO and Mayor Cell immediately.

Inspections and Controls

- Safety, Fire, and Force Protection inspections of living and working areas
- Commanders, leaders should conduct walk-through spot inspections
- Leaders ensure Soldiers are properly trained to recognize electrical hazards
- Soldiers enforce corrective measures to prevent electrical hazards



Point of Contact: Safety Officer or NCO _____

